



CITY OF SAN ANTONIO

DEVELOPMENT SERVICES DEPARTMENT

TO: All Development Services Department and Fire Department Customers

SUBJECT: **INFORMATION BULLETIN 119**
San Antonio Fire Department Policy on Aerial Fire Apparatus Access for R-1 and R-2 Occupancies

DATE: April 18, 2006

The San Antonio Fire Department (SAFD) has developed the following official policy for the design of aerial fire apparatus access roads for Groups R-1 and R-2 Occupancies. When designing aerial fire apparatus access roads for Groups R-1 and R-2 Occupancies, the design team may utilize the provisions of this policy with the provisions of Section D105.3 of the 2003 International Fire Code.

Should you have any questions regarding this policy, please contact Abel Flores - SAFD Fire Marshal at 210-207-7966

Attachment:

1. SAFD Policy on Aerial Fire Apparatus Access for Group R-2 Occupancies Policy # FP06005



CITY OF SAN ANTONIO

DEVELOPMENT AND BUSINESS SERVICES CENTER
FIRE PREVENTION DIVISION
1901 SOUTH ALAMO STREET
SAN ANTONIO, TEXAS 78204
(210) 207-8410 FAX: (210) 207-7949
TTY: (210) 207-4889

April 10, 2006

Policy #FP06005

Memorandum of Record

From: San Antonio Fire Marshal's Office

Subject: Fire code modification 2003 IFC section D105.3

It is the policy of the San Antonio Fire Marshal's office to allow the maximum distance allowed under section D105.3, aerial fire apparatus access roads proximity to building, to be increased from 30 feet to 39 feet for R1 and R2 occupancy classifications. All other occupancy classifications will still be limited to the 30 feet maximum distance per the 2003 IFC section D105.3

A handwritten signature in cursive script, appearing to read "Abel Flores".

Chief Abel Flores
Fire Marshal's Office
San Antonio, Texas